

### ANNEXURE-III

#### SCHOOL SANITARY CERTIFICATE

(Under the Tamil Nadu Education Rules)

#### APPENDIX - E

(Chapter III Rule - 24)

I hereby declare that I have inspected ESAKI VIDYAASHRAM SCHOOL (CBSE), TIRUNELVELI MAIN ROAD, VAIKAPAALAM, TENKASI 627811 TENKASI TALUK OF TENKASI DISTRICT building and Premises on 16.06.2025 and certify

- 1) That the accommodation provided for each of the several classes are sufficient for the minimum number of pupils taught there in and is properly ventilated and lighted.
- 2) That the latrine arrangements are adequate and maintained satisfactorily and also kept clean & maintain with the bleaching powder and phenyl.
- 3) That the supply of drinking water is wholesome and that in all other necessary aspects the sanitation is good.
- 4) Drinking water source should be chlorinated daily
- 5) That the building is maintained in substantial repair.
- 6) Adequate fire precautionary measures should be provided.
- 7) Adequate Emergency Exit should be provided.
- 8) Rain Water Harvest structure must be provided in the premises.
- 9) The water tanks (Sintex/Cement tank) in the campus should be kept clean by Protecting it from mosquitoes, the wastages like plastic items, broken bottles and Unused tyres should be replaced immediately from the rain water. Check every time whether the rain water staged in the terrace.
- 10) In School campus display of sign boards of size 60x30 cm (No Smoking area smoking here is an offence) inside the School.
- 11) In School campus no sale of tobacco in the radius of within 100 yards in the school

**MANAGER**  
**ESAKI VIDYAASHRAM**

Tenkasi - Tirunelveli Main Road,  
Vaikapaalam, Tenkasi - 627811



**Dr. T. SRINIVASAN**  
M.Sc., M.Phil., M.Ed., Ph.D., SET/LS, B.L.Sc.,  
PRINCIPAL  
**ESAKI VIDYAASHRAM**  
(AFF. to CBSE/AFF NO: 1930680)  
VAIKAPAALAM, TENKASI - 627811 (TN)

12) Conditions to be followed as per R.No.86684/EPI/S1/2020, dated 07.11.2020

(Instruction of the Chief Secretary meeting regarding SOP of School reopening held on 05.11.2020)

13) Proper cleaning and sanitization should be done at the School premises frequently and it should be recorded in a register.

14) Hand Sanitizers should be available in each Class room

15) The entire pupils in the School should be screened by IR Thermal scanner daily.

16) That essentials such as sanitizers, thermal scanner, disinfectants should be available in the premises sufficiently.

17) Hand washing facilities should be made in front of each and every building in the School.


18) Social distancing (atleast 6 feet) should be maintained at all places in the campus.

19) IEC materials regarding covid -19 Preventive measure should be displayed at appropriate places to create awareness

20) No persons/Students without face mask should be allowed in the campus.

21) The school should follow the SOP's updated by the Government then and there

22) This Certificate is valid for one year from the date of issue



BLOCK HEALTH SUPERVISOR

GOVT. Primary Health Centre

Vadakaraikilpidagai

L.Dis.No 5381/A5/ 2025

Dt


16/6/25

COUNTERSIGNED

(Based on Inspection Report of BHS. Dt.16.06.2025)

Technical PA to DHO

Tenkasi.



District Health Officer

Tenkasi.



16/6/25



16/6/25

DR. T. SRINIVASAN  
PERSONAL  
ESAKI VIDYASRAM  
VADAKARA  
VADAKARA

MANAGER  
ESAKI VIDYASRAM  
VADAKARA  
VADAKARA





**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD**  
**DISTRICT WATER TESTING LABORATORY**  
 Seevalaperi road, Shanthi nagar, Palayamkottai, Tirunelveli-627002.

Phone: 0462-2914676

Email: jwadwtltvl@gmail.com



TC - 15037

**TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 00192-1	Report Issue Date :	05.06.2025	Page No : 01 of 01
Invoice Details:	878 /Dt.04.06.2025 Amt.Rs.1652/-	ULR No	TC150372500000192F	

Client Name & Address	:	The Principal,
Contact No / Email.ID	:	Esaki Vidyaashramam CBSE School,
	:	Vaikapalam, Tenkasi.
Sample Name	:	Water -Open well water
Sample Number	:	00192 -1
Sample Description	:	Clear, Colour less Liquid
Sample Submitted by	:	Thiru. N. Santhosh Kumar
Location & Date	:	Above address & 04.06.2025
Quantity of sample Received	:	2 Litres
Sample Container	:	Jerry Cane
Sample Condition on Receipt	:	Good
Sample Received On	:	04.06.2025
Test Commenced on	:	04.06.2025
Test Completed on	:	05.06.2025

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1.	pH @ 25 <sup>o</sup> C	-	IS 3025 Part 11-2022	6.75	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025 Part 21-2009	19	200	600
3	Total Alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025-Part 23 -2023	32	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	16	250	1000
5	Sulphate as SO <sub>4</sub>	mg/L	IS 3025-Part 24—2022 Sec (1) - (Turbidity Method)	< 5	200	400
6	Nitrate as NO <sub>3</sub>	mg/L	APHA 24 <sup>th</sup> Edition 2023- 4500 -NO3 B	5	45	45
7	Fluoride as F	mg/L	APHA 24 <sup>th</sup> Edition 2023 - 4500- F-D	< 0.2	1.0	1.5

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2019) Drinking water Acceptable Limit specification with respect to above tested parameters.

.....End of the Report.....

**MANAGER**  
**ESAKI VIDYAASHRAM**

Tenkasi - Tirunelveli Main Road,  
 Vaikapaalam, Tenkasi - 627811

Reviewed & Authorised Signatory  
 S. Satesh Kumar B.Sc.,  
 Junior water Analyst.

**Dr.T.SRINIVASAN**  
 B.Sc., B.L.Sc.,  
 PRINCIPAL  
**ESAKI VIDYAASHRAM**

(AFF. to CBSE/AFF NO: 1930680)  
 VAIKAPAALAM, TENKASI - 627002 (TN)

**Note:**

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test sample will be retained for 15 days.
4. The result applied to the sample as received basis.





## TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

Seevalaperi road, Shanthi nagar, Palayamkottai, Tirunelveli-627002.

Phone: 0462-2914676

Email:jwadwltvl@gmail.com

## TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 00192 -2	Report Issue Date :	05.06.2025	Page No : 01 of 01
Invoice Details:	878 /Dt.04.06.2025 Amt.Rs.1652/-			

Client Name & Address Contact No / Email.ID	: The Principal, Esaki Vidyaashramam CBSE School, Vaikapalam, Tenkasi.
--	--

Sample Name	: Water -Open well water
Sample Number	: 00192 -2
Sample Description	: Clear, Colour less Liquid
Sample Submitted by	: Thiru. N. Santhosh Kumar
Location & Date	: Above address & 04.06.2025
Quantity of sample Received	: 2 Litres
Sample Container	: Jerry Cane
Sample Condition on Receipt.	: Good
Sample Received On	: 04.06.2025
Test Commenced on	: 04.06.2025
Test Completed on	: 05.06.2025

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Odour	IS 3025 Part 5 : 1983	--	Agreeable	Agreeable	Agreeable
3	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	2	1	5
4	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	87	500	2000
5	Conductivity	APHA 23rd Edition 2017 - 2510 B	$\mu$ S/cm	128	-	-
6	P - Alkalinity	IS 3025-Part 23-1983	mg/L	NIL	-	-
7	Calcium as Ca	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	4	75	200
8	Magnesium as Mg	APHA 23rd Edition 2017- 3500 Mg B	mg/L	2	30	100
9	Iron as Fe	APHA 23rd Edition 2017- 3500 Fe B	mg/L	< 0.01	0.3	1
10	Manganese as Mn	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	-	0.1	0.3
11	Ammonia as NH <sub>3</sub>	APHA 17th Edition-1989- 4500 NH <sub>3</sub> C	mg/L	< 0.01	0.5	0.5

## Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.

**MANAGER****ESAKI VIDYAASHRAMAM**Tenkasi, Tirunelveli Main Road,  
Vaikapalam, Tenkasi - 627811**Dr.T.SRINIVASAN**

M.Sc., M.Phil, M.Ed., Ph.D., SET(ES), B.U.Sc.,

**ESAKI VIDYAASHRAMAM**

(AFF.to CBSE/AFF NO: 1910650)

VAIKAPALAM, TENKASI - 627811 (TN)



# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

Seevalaperi road, Shanthi nagar, Palayamkottai, Tirunelveli-627002.

Phone: 0462-2914676

Email: jwadtltvl@gmail.com

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 00192 -2	Report Issue Date :	05.06.2025	Page No : 01 of 01
Invoice Details:	878 /DL.04.06.2025 Amt.Rs.1652/-			

S. No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
12	Nitrite as NO <sub>2</sub>	APHA 23rd Edition 2017- 4500-NO2 B	mg/L	0.02	-	-
13	Total Phosphate as PO <sub>4</sub>	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.03	-	-
14	Tidys 4 hr. test	APHA 23rd Edition 2017 -- 4500 O - B	mg/L	0.24	-	-
15	Residual Chlorine	IS/APHA	mg/L	0	0.2	1.0
BACTERIOLOGICAL EXAMINATION						
16	Fecal Coliform	IS/APHA	CFU/ 100ML	0	0	0

Result: The given water sample is chemically potable.

.....End of the report.....

**MANAGER**  
**ESAKI VIDYAASHRAM**

Tenkasi - Tirunelveli Main Road,  
Vaikapaalam, Tenkasi - 627811

**JUNIOR WATER ANALYST**  
D.W.T. LAB, TWAD BOARD,  
T.T.K. CIRCLE, TIRUNELVELI.

**Dr.T.SRINIVASAN**  
M.Sc, M.Phil, M.Ed, Ph.D, SET(UL), B.J.Sc,  
**PRINCIPAL**  
**ESAKI VIDYAASHRAM**  
(AFF.to CBSE/AFF NO: 1930680)  
VAIKAPAALAM, TENKASI - 627811 (TN)

#### Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.